

BELZONA® MEMBRANE SEALS DIGESTER ROOF SEAMS

CUSTOMER

Wastewater Treatment Facility



APPLICATION DATE

July 2004

PROBLEM

The rubber type seal between the brick wall and walkway surrounding the digester tank had broken down allowing water to seep below into an electrical room.

PRODUCTS

Belzona® 3111 Flexible Membrane

SUBSTRATE

Concrete / Brick / Rubber membrane

APPLICATION METHOD

Application carried out in accordance with Belzona® Know-How Leaflet RPA-1

BELZONA FACTS

Belzona 3111 Flexible Membrane can be successfully bonded to the 3 different substrates and eliminated the necessity to remove the rubber membrane sheet.

PHOTOGRAPHS

1. View of existing membrane.
2. Application of 1st coat in progress complete with reinforcement sheet.
3. Completed application

